

Deduction meters For Use with Town of Tiverton Permitted Irrigation System

The TWWD Deduction Meter Policy revised 2024 requires use of a Badger 25 with Manual Register, 5/8in x 3/4 in. Or suitable equivalent approved by TWWD.

[IDM-DS-00113-EN_Recordall Nutating Disc Meter, Bronze & Thermoplastic Product Data Sheet.pdf](#)

The Recordall Disc Series meters meet or exceed the most recent revision of AWWA Standard C700.

PERFORMANCE

- Accuracy: $\pm 1.5\%$
- Repeatability: $\pm 0.5\%$
- Pressure Range: up to 150 psi
- Temperature Range: 32...250° F

Installation Manual [RCDL-manual.pdf \(instrumart.com\)](#)

Other Flow meters used by customers and approved by TWWD, include:

Hunter HC Flow meter <https://support.hydrawise.com/hc/en-us/articles/115000902207-HC-Flow-Meter-Specifications>

ME-PD NTEP Approved Positive Displacement Water Meter
<https://www.flows.com/content/literature/Datasheets/ME-PD-datasheet.pdf>

Neptune model T-10

[PS-T10-SMALL-23-010383-07-23.pdf \(neptunetg.com\)](#)

Assured Automation model WM-NLC-075

[WM-NLC_datasheet.pdf \(assuredautomation.com\)](#)